


EXTERIOR PLAN

NOTES

- 1.) CONTROL WIRES (5)-14 AWG WIRES BETWEEN THE FLOW METER AND THE CONTROLLER ENCLOSURE.
- 2.) ALL WELDS TO BE CONTINUOUS AND GROUND SMOOTH. PAINT ENCLOSURE AND PEDESTAL WITH 2 COATS ASA 61 GREY URETHANE ALKYD GLOSS PAINT, INSIDE AND OUTSIDE SURFACES.

		DATE:	June 6, 2016	PARKS & RECREATION 	TITLE:	BOOSTER PUMP STATION DETAILS	
		SCALE:	N.T.S.		DWG No.:		PK216b
		DRAWN:	A.B.		Rev.:		
No	YY MM DD DATE	REVISION DESCRIPTION	BY	APPROVED:	M.M.		