


**NOTES**

- 1.) CONTROL WIRES (5)-14 AWG WIRES BETWEEN THE FLOW METER AND THE CONTROLLER ENCLOSURE.
- 2.) ALL WELDS TO BE CONTINUOUS AND GROUND SMOOTH. PAINT EXPOSURE AND PEDESTAL WITH 2 COATS ASA 61 GREY URETHANE ALKYO GLOSS PAINT, INSIDE AND OUTSIDE SURFACES.

		DATE:	June 6, 2016	<b>PARKS &amp; RECREATION</b>  	TITLE:	<b>BOOSTER PUMP STATION DETAILS</b>	
		SCALE:	N.T.S.				
		DRAWN:	A.B.				
No	YY MM DD DATE	REVISION DESCRIPTION	BY	APPROVED:	M.M.	DWG No.: <b>PK215b</b>	Rev.: